



CLINT QUILTER
DIRECTOR
cquilter@inyocounty.us

DEPARTMENT OF PUBLIC WORKS
168 N. Edwards Street, Independence, CA 93526
760-878-0201

SHANNON WILLIAMS
DEPUTY DIRECTOR
swilliams@inyocounty.us

ADDENDUM NO. 1
TO THE PLANS AND SPECIFICATIONS FOR
COUNTY BUILDINGS ROOFING PROJECT

August 25, 2017


This addendum is being issued to notify bidders of the following:

1. At Progress House: Inyo County Maintenance will raise the height of the evaporative cooler (on the east end of the house) by 6 inches. This will allow the foam to be applied without the need for the contractor to move the unit. The cooler at the west end of the house is already at an acceptable height.
2. At Statham Hall: There is currently a heater unit and gas lines which are not shown in the drawings, these will both be removed by Inyo County Maintenance before the project commences. The gas lines will be replaced by Maintenance as soon as the project at Statham has finished. County personnel will also help the contractor lift the large cooling unit shown on the drawings, in order to spray underneath.

Receipt of this addendum should be acknowledged by **inserting the number and the date of receipt on page 3** of the Bid Proposal Form. Failure to acknowledge receipt of this addendum on the Bid Proposal Form may be considered grounds for rejection of the bid.

If a bid is submitted, it should be with the understanding that the revisions contained herein are incorporated into the plans and specifications for the project and form a part of the contract to be executed for this work. It is requested that any contractors or subcontractors that may have been given plans or specifications for this project be advised of these contract revisions.

Inyo County
Department of Public Works



Ashley Helms
Engineering Assistant, Public Works

August 25, 2017
Date

Chris Cash
Road Superintendent
760-878-0451
ccash@inyocounty.us

Jerry Poole
Associate Building Official
760-873-7858
jpoole@inyocounty.us