

ADDENDUM NO. 1
TO THE SPECIFICATIONS FOR
Diaz Lake Welcoming and Beautification Project

Subject: Addendum – Playground Design Specifications & Information

Date: September 17, 2024

To All Concerned Parties,

This addendum is being issued to notify all prospective bidders about playground design specifications for the Diaz Lake Welcoming and Beautification Project. Inyo County prefers a playground that is not a typical "cut & paste" playground. A smaller plastic playset with additional free-standing features is preferred. Project designs with redundant slides or large amount of plastic features will be rejected. The design for the playground **must** contain the following:

- 1) Swing set with attachments for ADA and normal seating; closest to the ADA parking area
- 2) Climbing features/walls, balance beams, optional zipline/trolley mechanism, and creative play areas for children 5-12
- 3) Shade system to cover a majority of the play area (Please ensure the shade system meets or exceeds Inyo County Wind Ordinance)

The list below shows URL's for features that are examples of what Inyo County Parks and Recreation is looking for:

- 1) Climbing Rock - https://willygoat.com/products/naturerocks-granite-climbing-boulder?variant=31072026853473&utm_source=google&utm_medium=cpc&utm_campaign=Google%20Shopping&stkn=ff1d4e32b302&campaignid=17545635763&keyword=&device=c&adtype=pla&adgroupid=&gad_source=1&gclid=EAiaIQobChMI8b2ek-bKiAMVPQCtBh1scSBIEAQYASABEgJKU_D_BwE
- 2) Rope Tower - <https://www.gametime.com/products/vistasky-rope-tower-2>
- 3) Dome Climber - <https://www.gametime.com/products/dome-climber-655>
- 4) Climbing Cave - <https://www.gametime.com/products/discover-cave-with-primary-grips-5052>

Updates to Scope of Work under VII. Playground Specifications, page 48 of the Bid Package, page 10 of the Special Provisions.

5a) Picnic areas should be 6 inches thick, minimum 16ft x 16ft with ½ inch rebar reinforcement at perimeter

6a) Seating area should be 6 inches thick, minimum 16ft x 16ft with ½ inch rebar reinforcement at perimeter

All other terms and conditions outlined in the original bid documents remain unchanged. Any inquiries or requests for clarification should be directed to the contact person specified in the original bid documents.

Thank you for your interest in the Diaz Lake Welcoming and Beautification Project.

Sincerely,

Daniel Briceño

Parks and Recreation Manager, Inyo County